



Americans with Disabilities Office General Services Department

Accessibility Survey

Date: November 13, 2009

Location: Salmon Creek Wastewater Treatment Plant



Survey Team:

Wayne Yarnall
 Trenton Hanson

Jesse Magana
 Dave Maret

Laura Pedersen
 Tim McVicker

Observations:

Photo Orientation	Code - Remarks
	<p>Item # 1</p> <p>Issue: Height of accessible parking signs</p> <p>Issue:</p> <p>Location: All parking signs</p> <p>Code: ANSI 502.7 Identification: Where accessible parking spaces are required to be identified by signs, the signs shall include the International Symbol of Accessibility complying with Section 703.6.3.1. Signs identifying van parking spaces shall contain the designation "van accessible." Such signs shall be 60 inches (1525 mm) minimum above the floor of the parking space, measured to the bottom of the sign</p> <p>Notes:</p>
	<p>Item # 2</p> <p>Issue: Van accessible parking sign (South stall)</p> <p>Issue:</p> <p>Location: Accessible parking area</p> <p>Code: ANSI 502.7 Identification: Where accessible parking spaces are required to be identified by signs, the signs shall include the International Symbol of Accessibility complying with Section 703.6.3.1. Signs identifying van parking spaces shall contain the designation "van accessible." Such signs shall be 60 inches (1525 mm) minimum above the floor of the parking space, measured to the bottom of the sign</p> <p>Notes:</p>



Item # 3

Issue: Restroom Signage

Issue:

Location: Eugene Fix Building – Restroom Near Lobby

Code: ANSI 703 Signs – Please refer to ANSI Standards for complete sign requirements.

ANSI – 703.3.11 Location – Where a tactile sign is provided at a door, the sign shall be alongside the door at the latch side.

ANSI – 703.3.10 – Height Above Floor – Tactile characters shall be 48 inches minimum above the floor, measured to the baseline of the lowest tactile character and 60 inches maximum above the floor, measured to the baseline of the highest tactile character.

Notes: Currently signage identifying accessible restrooms is on restroom doors of the men's and women's 1st floor public restrooms.

Code:



Item # 4

Issue: Vertical Grab Bar

Issue:

Location: Eugene Fix Building – Restroom Near Lobby

Code: ANSI 604.5.1 A vertical grab bar 18 inches minimum in length shall be mounted with the bottom of the bar located between 39" and 41" above the floor, and with the center line of the bar located between 39" and 41" from the rear wall.

Notes: