



NOTES:

1. LEVEL SPREADERS SHALL BE INSTALLED AT A MINIMUM INTERVAL OF 50', TO KEEP THE FLOWS FROM CONCENTRATING. THE SPREADER SHALL BE INSTALLED LEVEL AND ON CONTOUR.
2. CONCRETE SPREADER SHALL BE CAST-IN-PLACE. TOP OF SPREADER SHALL BE BROOM FINISHED IN THE DIRECTION OF FLOW.
3. SEE STD. DETAIL D11.2 FOR SEED MIX.

NO.	REVISIONS	DATE	BY

DWG: D11.4.DWG



Department of
 Public Works
CLARK COUNTY
 WASHINGTON
 proud past, promising future

FLOW SPREADER CURB

APPROVED
 COUNTY ENGINEER

01/07/16
 DATE

STANDARD
D11.4
 DETAIL
 DESIGNED
 DRAWN
 DATE 01/30/15