



**NOTES:**

1. FOR INSTALLATION OF DRAINAGE PIPE IN NEW DEVELOPMENT.
2. GENERAL PIPE INSTALLATION REQUIREMENTS SHALL BE PER SECTION 7-08 OF WSDOT STANDARD SPECIFICATIONS.
3. TRENCH BACK FILL SHALL CONFORM TO CCC 40.350.030(C)(4)(e).
4. PIPE ZONE AND BEDDING MATERIAL SHALL CONFORM TO WSDOT STANDARD SPECIFICATIONS 9-03.12(3)
5. GRAVEL BACKFILL PER WSDOT SPECIFICATIONS SECTION 9-03.19, AND COMPACTED TO 95% MAX. DENSITY (AASHTO T-99). NATIVE SOILS MAY BE USED UPON APPROVAL BY REVIEWING AUTHORITY IF TESTING SHOWS MATERIAL IS CLASSIFIED AS A-1 OR A-3 BY AASHTO.
6. OUTSIDE THE ROADWAY PRISM, SUITABLE NATIVE BACKFILL SHALL BE COMPACTED TO 90% MAX. DENSITY (AASHTO T-99).
7. ALL COMPACTION SHALL BE IN ACCORDANCE WITH THE COMPACTION CONTROL TEST OF WSDOT STANDARD SPECIFICATIONS 2-03.3(14)D.
8. CONTACT CCPW FOR NATIVE MATERIAL FOR TRENCH BACKFILL APPROVAL FORM.

DWG: D14.DWG

NO.	REVISIONS	DATE	BY



Department of Public Works  
**CLARK COUNTY WASHINGTON**  
 proud past, promising future

PIPE BEDDING AND BACKFILL

*[Signature]* APPROVED  
 COUNTY ENGINEER

01/07/16  
 DATE

STANDARD  
**D14**  
 DETAIL  
 DESIGNED  
 DRAWN  
 DATE 01/30/15