



**NOTES:**

1. DITCH INLET CONSTRUCTION IN ACCORDANCE WITH ASTM C-478.
2. CATCH BASIN, FRAME, AND GRATES SHALL BE FLAT BAR STEEL OR APPROVED EQUAL.
3. INSIDE FRAME DIMENSIONS: 2'-3 3/8"x 2'-8 1/2".
4. 3/8" CROSS BARS SHALL BE FLUSH WITH THE GRATE SURFACE AND MAY BE FILLET WELDED, RESISTANCE WELDED OR ELECTROFORGED TO BEARING BARS.

NO.	REVISIONS	DATE	BY

DWG: D6.DWG



Department of  
Public Works  
**CLARK COUNTY**  
WASHINGTON  
proud past, promising future

CONCRETE DITCH INLET

*[Signature]*  
APPROVED  
COUNTY ENGINEER

01/07/16  
DATE

STANDARD  
**D6**  
DETAIL  
DESIGNED  
DRAWN  
DATE 01/30/15