

Clark County Public Works

Bid Inquiry Log

Last Update: November 7, 2023

Responses will be posted on the project's "Bid Inquiry Log", which will be updated twice daily, at noon and 6:00 PM. The Bid Inquiry log will display all questions and answers to the questions that have accumulated by the posting time. Questions too late to be answered as of that posting will remain unanswered. The questions and answers posted on the Bid Inquiry Log at that time will be considered part of the contract and ranked as an Addendum with respect to order of precedence under Section 1-04.2 of the Standard Specification.

Project CRP #:	372122
Title:	NE 68th Street Sidewalk
Engineer In Charge:	Bart Arthur

Date: 10/26/23
Question #1: The excavation of the crushed surfacing reservoir course section is incidental to what line item?
Reference: D07 & D08
Answer: **Bid item 19 and 119 Roadway excavation is where this excavation will be paid.**

Date: 10/27/23
Question #2: In the Bid Schedule, the shoring wall refers to the specification section 6-16, but while searching the spec section, section 6-16 is not present. Is the shoring wall references under a different spec section, or is it just missing?
Reference: Not identified
Answer: **Section 6-16 is a standard specification and applies to this work. Reference the Standard Specifications M41-10 2023.**

Date: 10/30/23
Question #3: 160 working days seems to be tight with regards to this project, how will the winter weather be accounted for.
Reference: 1-08.5
Answer: **Clark County is flexible and will consider a winter shut down once the clearing work needed to accommodate the utility relocations has been accomplished. The County's intent is to obtain physical completion in 2024.**

Date: November 1, 2023
Question #4: Please provide a detail for bid item 45 Trench Dam Type Concrete.
Reference: Proposal form
Answer: See addendum 2, item for Trench Dam Type Concrete delted

Date: November 2, 2023
Question #5: With the realistic start date of April 2024, would it be possible to postpone the bid by 1-2 weeks???
Reference: Not provided
Answer: The bid is not being postponed, bids due Nov the as per the NTC

Date: November 3, 2023
Question #6: Respectfully requesting a bid opening date extension.
Reference: Not provided
Answer: The bid is not being postponed, bids due Nov the as per the NTC

Date: November 3, 2023
Question #7: The planting schedule requires all planting to be done between Nov 1st and Dec 31st. Backing up from Dec 20th using 160 work days develops a contract start date of March 15th 2024. However, in prior questions, it appears the project is anticipated to start before this time frame as a discussion of winter weather is provided. Please clarify the anticipated start date and if this is earlier than March 15th, will a shut down be provided following the project completion to allow for planting.
Reference: 8-02.3(8) A - Planting
Answer: See the answer to question 3.

Date: November 4, 2023
Question #8: What are the pay limits of the gravel borrow for both line items 20 and 119? The walls are design build so how is the gravel borrow quantity calculated unless its to back of wall since there is no wall design, specifically under the city of Vancouver section of the bid.
Reference: Proposal form
Answer: Gravel Borrow is to be used for embankment. SEW backfill is paid as part of the wall SF.

Date: November 4, 2023
Question #9: Sheet D17 shows a hatch pattern under the valley gutter on the city drawing D17. the hatch pattern appears to be at least 2' thick but is not called out with any notes. Is this just the base rock section drawn out of scale?
Reference: Sheet D17
Answer: Please see the detailed dimension for the Valley Gutter to the left bottom on D17 City of Vancouver drawings.

Date:

November 7, 2023

Question #9:

I see that Federal Wage Rate modification #5 has been released, does this impact wage rates in Clark County?

Reference:

Answer:

Federal Wage Rate modification #5 has been released. This modification does not impact wage rates for work in Clark County.
