



# ADA Compliance Program

## Clark County Facilities Transition Plan Clark County Amphitheater

Date of Survey: October 16, 2008  
 Conducted by: Clark County Citizen ADA Advisory Board

- Wayne Yarnall
- Jesse Magana
- Bud Van Cleve
- Tim McVicker
- Trenton Hansen
- Dave Maret

Note: A good-faith assessment was conducted of this building by the Clark County Citizen ADA Advisory Committee. The Clark County Amphitheater was constructed in 2002.

	<p><b>Item: Contrast of Detectible Warning Surface</b>  <b>Location:</b> East Parking Lot – Disabled Parking Only</p> <p><b>Code: ANSI 705.3 Contrast</b> - Detectable warning surfaces shall contrast visually with adjacent surfaces, either light-on-dark or dark-on-light.</p> <p><b>Note:</b></p> <ul style="list-style-type: none"> <li>- Truncated domes and accessible pathways leading into vehicular hazard areas are the same color.</li> <li>- Truncated domes are deteriorating</li> </ul>	
	<p><b>Item: Drinking Fountain Barriers</b>  <b>Location:</b></p> <ul style="list-style-type: none"> <li>- East Plaza Restroom</li> <li>- North Plaza Restroom</li> </ul> <p><b>Code: ANSI 307.2 Protrusion Limits.</b> Objects with leading edges more than 27 inches and not more than 80 inches above the floor shall protrude 4 inches maximum horizontally into the circulation path. The drinking fountain shown protrudes 11 inches and the height shown is 32 3/8 inches.</p> <p><b>Note:</b> It is recommended that benches be placed adjacent to the drinking fountains to serve as a barrier.</p>	<p style="text-align: center;">Fig. 307.2 Limits of Protruding Objects</p>



**Item: Restroom Mirror Height**

**Location:** East Plaza Restroom – Women’s Restroom – Accessible Sink - South Side

**Note:** Current Height: 46”

**Code: ANSI 603.3 Mirrors** - Mirrors located above lavatories, sinks or counters shall be mounted with the bottom edge of the reflecting surface 40 inches (1015 mm) maximum above the floor. Mirrors not located above lavatories, sinks or counters shall be mounted with the bottom edge of the reflecting surface 35 inches (890 mm) maximum above the floor.



**Item: Access to Operable Parts – Hand Towel Dispenser**

**Locations:**

- East Plaza Restroom – Women’s Restroom – Accessible Sink South Side – Height 53.5”
- East Plaza Restroom – Men’s Restroom – Accessible Sink West Side – Height 50”
- North Plaza Restroom – Women’s Restroom – Accessible Sink East Side – Height 54”
- VIP Restrooms – Men’s and Women’s – Current height 52”

**Code ANSI 308.2 Forward Reach**

**Code: ANSI 308.2.1 Unobstructed** - Where a forward reach is unobstructed, the high forward reach shall be 48 inches (1220 mm) maximum and the low forward reach shall be 15 inches minimum above the floor.