



# Americans with Disabilities Office General Services Department

## Accessibility Survey

**Date: November 3, 2009**

**Location: Hamilton Building**

**Survey Team:**

Wayne Yarnall

Trenton Hanson

Jesse Magana



Dave Maret

Laura Pedersen

Tim McVicker

**Observations:**

Photo Orientation	Code - Remarks
	<p>Item #      1</p> <p>Issue:      Flush Handle Location</p> <p>Issue:</p> <p>Location:    Public Men's Restroom – 1<sup>st</sup> Floor Lobby</p> <p>Code:        ANSI 604.10.6 - Flush Controls - Flush controls shall be hand operated or automatic. Hand operated flush controls shall comply with Sections 309.2 and 309.4 and shall be installed 36 inches maximum above the floor. Flush controls shall be located on the open side of the water closet.</p> <p>Notes:</p>
	<p>Item #      2</p> <p>Issue:      Toilet Seat Height</p> <p>Issue:</p> <p>Location:    Public Men's Restroom – 1<sup>st</sup> Floor Lobby</p> <p>Code:        ANSI 604.4 – The height of water closet seats shall be 17" minimum and 19" maximum above the floor measured to the top of the seat.</p> <p>Notes:        Current height 16.25"</p>
	<p>Item #      3</p> <p>Issue:      Vertical Grab Bar</p> <p>Issue:</p>

	<p>Location: Public Men's Restroom – 1<sup>st</sup> Floor Lobby</p> <p>Code: ANSI: 604.5.1 A vertical grab bar 18 inches minimum in length shall be mounted with the bottom of the bar located between 39" and 41" above the floor, and with the center line of the bar located between 39" and 41" from the rear wall.</p> <p>Notes:</p>
<p><b>No Photo</b></p>	<p>Item # 4</p> <p>Issue: Vertical Grab Bar</p> <p>Issue:</p> <p>Location: Women's Public Restroom – 1<sup>st</sup> Floor Lobby</p> <p>Code: ANSI: 604.5.1 A vertical grab bar 18 inches minimum in length shall be mounted with the bottom of the bar located between 39" and 41" above the floor, and with the center line of the bar located between 39" and 41" from the rear wall.</p> <p>Notes:</p>
	<p>Item # 5</p> <p>Issue: Telephone Access (Blocked by Table and Chairs)</p> <p>Issue:</p> <p>Location: 2<sup>nd</sup> Floor Lobby</p> <p>Code: ANSI 704.2.1 Clear Floor Space – A clear floor space complying with Section 305 shall be provided. The clear floor space shall not be obstructed by bases, enclosures or seats.</p> <p>Notes:</p>
	<p>Item # 6</p> <p>Issue: Accessible Entrance</p> <p>Issue:</p> <p>Location: East entrance (Main Entrance)</p> <p>Code: IBC 1110.1 - Signs Required Accessible elements shall be identified by the International Symbol of Accessibility at the following locations:</p> <ul style="list-style-type: none"> <li>• Accessible entrances where not all entrances are accessible.</li> </ul> <p>Notes:</p>