



Clark County 2015 Stormwater Manual Implementation Summary of Procedure

This procedure statement documents discussions and decisions from Environmental Services, Community Development, Public Works and Prosecuting Attorney's office. Implementation of new stormwater regulations require staff to work through specific details of the regulations with applicants. The purpose is to ensure consistent application of county requirements. These procedure statements document decisions for future reference and will be kept on the [ClarkNet web page](#) (Environmental Services).

Procedure statement #2015-001 - March 9, 2016

Sign placement for BMP features

Book	Section	Page	Issue	Decision
1	1.6	37	The manual states standard sign size and placement for stormwater signage to be placed at all new stormwater facilities. PUD requires a smaller sign if it is to be placed on a utility pole (12" x 16"). How to address changes from the stated standards in the manual.	The language in the CCSWM refers to other code if there is a need for changes. It is the intent of the language to allow modifications of size and location based site specific conditions including safety, visibility and need. This group agrees that if signs are to be placed on PUD poles, the smaller 12"x16" size is acceptable. Other modifications can be considered by the reviewing staff to best fit the proposed site development conditions.