

Clark County Public Works

Bid Inquiry Log

Last Update: April 27, 2020

Responses will be posted on the project's "Bid Inquiry Log", which will be updated twice daily, at noon and 6:00 PM. The Bid Inquiry log will display all questions and answers to the questions that have accumulated by the posting time. Questions too late to be answered as of that posting will remain unanswered. The questions and answers posted on the Bid Inquiry Log at that time will be considered part of the contract and ranked as an Addendum with respect to order of precedence under Section 1-04.2 of the Standard Specification.

Project CRP #:	381522
Title:	Smith Bridge #211 – Scour Mitigation
Engineer In Charge:	Michael Tracy

Date: 4/27/20

Question #1: It says we need to turn in a good faith efforts document, and I don't see one in the documents. Any idea where I could find this?

Reference:

Answer: There is no explicit form provided to document good faith efforts. Attention should also be made explicitly follow the directions noted on the bid forms (and the corresponding specifications/ special provisions) and clearly indicate if GFE are being submitted in lieu of UDBE utilization. Also refer to section 1-07.11 in the special provisions.

Date: 4/27/20

Question #2: Will pre-batched streambed materials be acceptable for line items 38-40? The special provision note that that each material type is to be brought in separately and measured before being batched and placed on site, but most places offer streambed materials pre-batched.

Reference:

Answer: Bid the contract as specified. But Clark County would not be opposed to the idea of allowing the use of prebatched materials if the contractor could document/ verify the prebatched materials are in compliance with the specified gradations noted in the plans and specifications.

Date:

Question #3:

Reference:

Answer:

Date:
Question #4:
Reference:
Answer:

Date:
Question #5:
Reference:
Answer:
